

CivilTech Services

Project No.: 15-015

18 November 2015

Kopegaron Woods Boardwalk Replacement Addendum #1

Tenderers:

The following items comprise Addendum #1 for the above-noted project. Where applicable, specific changes to the text of the original Tender Documents are noted in *italicized* font for your convenience.

A1.0 Clarifications to the Construction Drawings

A1.1 – Drawing No. S1 Boardwalk Details

- General Note No. 8 shall be deleted in its entirety and replaced with the following note:

“Steel – Steel to be 350W, shop painted with two coats of red oxide primer. Touch up all areas damaged during installation.”

A2.0 Clarifications to the Construction Specifications

A2.1 – Section 4 Special Provisions

Please note the following revisions to the Scope of Work section of the Special Provisions:

2.2 Supply and Install Boardwalk Supports

The following text shall be added to the end of the section:

All structural steel shall be shop painted with two coats of red oxide primer. The primer shall be applied in accordance with the manufacturer’s specifications. All areas damaged during installation and all field welds (if any) shall be touched-up on-site.

I trust that you will find the foregoing to be in order. Please call if you have any questions or concerns.

Yours truly,

CivilTech Services

A handwritten signature in black ink that reads "M. Ladarski". The signature is written in a cursive, flowing style.

Michael S. Ladarski, C.E.T.

cc. All Prospective Tenderers
Kevin Money - ERCA